



HIGHLANDS COUNTY  
BOARD OF COUNTY COMMISSIONERS  
(HCBCC)  
GENERAL SERVICES & PURCHASING

**DATE:** June 18, 2009

**BID NO.** ITB 09-048 **ADDENDUM NO. 1**

**Project.:** Mast Arms Foundations for Signalized Intersection  
Sebring Parkway @ Center Avenue  
Project No. 01101

**Owner:** Highlands County BCC  
Attn: Purchasing Department  
4320 George Blvd; Sebring, FL 33875-5803

1. The orientation of the conduit stub outs shall be determined and approved by Highlands County Traffic Operations.
2. Elevation of the stub out of conduits shall be no more than 30" below final grade within 3' radius of foundation and no less than 24" below final grade.
3. Contractor is responsible to insure that anchor bolt threads are free of any concrete or other debris, by any means necessary, including tapping remaining threads so the anchor bolt nuts shall thread freely to tighten mast arm assemblies.

If you have any questions or comments regarding this addendum, contact:

Mr. Gerald (Jed) Secory, Director of General Services / Purchasing Department  
4320 George Boulevard; Sebring, Florida 33875-5803  
Phone (863) 402-6523, Fax (863) 402-6735, or by Email: [gsecory@hcbcc.org](mailto:gsecory@hcbcc.org)

Or: Danielle K. Gilbert, Purchasing Analyst, General Services / Purchasing Department  
Phone (863) 402-6524, Fax (863) 402-6769, Email: [dgilbert@hcbcc.org](mailto:dgilbert@hcbcc.org)

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY:  
COMPLETING BELOW INFORMATION AND FAXING TO: (863)-402-6735.

\_\_\_\_\_  
COMPANY NAME (PRINT)

\_\_\_\_\_  
REPRESENTATIVE (PRINT)

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
PHONE

\_\_\_\_\_  
ADDRESS

\_\_\_\_\_  
EMAIL